## **Street & Security Lighting – General Discussion**

All Street & Security Lights are provided on a rental basis to either government or private customers who request where, how many and what size lights are to be installed. CUC's involvement is to make available a power supply for the lights (underground or overhead), install, maintain, and if necessary take down.

All new and replacement luminaires will be light emitting diode (LED) fixtures. All existing high pressure sodium (HPS) fixtures are to be replaced on a program basis.

The standard luminaires for street lighting are:

<b>New LED Fixture</b>	<b>Existing HPS Fixture</b>
53 Watt	100 Watt
137 Watt	250 Watt
207 Watt	400 Watt

The mounting arrangements are:

- (1) 53 W LED with a 4 or 8 foot arm (Drawing 14-3)
- (2) 137 W LED with an 8 foot arm on a wood pole and a 6 foot arm on an aluminum pole (Drawing 14-4)
- (3) 207 W LED with an 8 foot arm; (Drawing 14-5)
- (4) A 53 W LED fixture shall be installed on poles at a height of 24'-6" (See Drawing 14-3); and the 137 W and 207 W luminaires shall be installed on poles at heights of 29'-6" and 32' respectively (See Drawings 14-4 and 14-5).

All street light arms shall be grounded at the pole; where no grounding arrangement exists the mounting bolt shall be grounded using a ground clip and nut. All grounds shall be connected to the pole ground where applicable.

A photo control shall be installed on all luminaires in the receptacle provided and shall have the photo eye pointing to the North. To change the orientation of the fixture receptacle, loosen the two screws, orient the receptacle and tighten both screws.

	Date: June 21, 2017	DISTRIBUTION STANDARDS	
	Drawn by: C. Rose		
		STREET & SECURITY LIGHTING	
You've got the power	Revision #: B		
457 North Sound Rd. P.O. Box 38 G.T., Grand Cayman,	Revision date: November 23, 2020	Approved date: December 7, 2020	STANDARD # 14-1
Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200	Revised by: N. Malcolm	Approved by: N. Malcolm	Page: 1 of 1

## Service & Street Lights - Overhead


# **Street Lights:**

Telephone: (345)-949-5300/5200

When planning for streetlights installations, the following optimization can be made without exceeding a voltage drop of 3% at the streetlight on the end of the circuit:

- 2/0 AAC bare conductors can be installed at a maximum distance of 2,000 feet between the transformer and the last streetlights; and a maximum of eighteen (18) 53 W LED streetlights, with each LED streetlight installs at approximately 200 feet interval. Similarly, a maximum of seven (7) 137 W LED streetlights can be accommodated with each light installs at approximately 200 feet interval; only four (4) 207 W LED streetlights at approximately 200 feet span can be installed. For greater number of LED streetlights, the secondary circuit shall be upgraded to 4/0 conductor.
- For shorter spans of 150 feet or less, and in areas requiring excessive tree trimming, #2 triplex should be considered for the overhead line supplying the streetlight.


You've got the power 457 North Sound Rd. P.O. Box 38 G.T., Grand Cayman, Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200	Date: June 21, 2017  Drawn by: C. Rose	DISTRIBUTION STANDARDS	
	Revision #: B	STREET & SECURITY LIGHTING	
	Revision date: November 23, 2020	Approved date: December 7, 2020	STANDARD # 14-2
	Revised by: N Malcolm	Approved by: N. Malcolm	Page: 1 of 1



ITEM	QUAN'	TITY	MATERIAL	GTO GIV NO
NO.	Galv.	SS	MATERIAL	STOCK NO.
78B		1	CRIMPIT - CTYPE, COPPER, #2-#6 AWG	253-00004
135E		1	BOLT - MACH. 5/8" x 12", SS	098-00039
143		1	NUT, SQUARE, 5/8", SS	565-00009
149		2	SCREW - LAG, TWIST DRIVE/DRIVE POINT, 1/2" X 3", SS	744-00003
153		1	WASHER - FLAT SQ., 2 1/4", 11/16" HOLE, SS	973-00009
158		1	WASHER - LOCK, 5/8", SINGLE COIL, SS	973-00010
162		1	CLIP-GROUND WIRE BONDING, 5/8", SS	188-00004
406A		1	ARM, LIGHT ALUMINUM - 2" X 4'	035-00001
408A		1	PHOTOCELL ELECTRONIC	597-00001
412		2	CONNECTOR, INSULATED PIERCING, TYPE EPB	213-00027
415		1	LUMINAIRE, LED 54W	520-00005

- 1. Enough slack shall be left in the cable to provide a loop to ensure that the cable does not chafe against the bracket.
- 2. Each streetlight shall be grounded inside the luminaire and also the ground shall be connected to the neutral on both primary and secondary poles.


	Date: September 2017  Drawn by: D. Moore	DISTRIBUTION STANDARDS	
You've got the power	Revision #: B	54W LED 4FT. ARM INSTALLATION	
457 North Sound Rd.	Revision date: November 23, 2020	Approved data: November 22, 2020	STANDARD # 14-3
P.O. Box 38 G.T., Grand Cayman, Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200	Revision date. November 23, 2020	Approved date: November 23, 2020	51ANDAKD # 14-3
	Revised by: C. Craig	Approved by: N. Malcolm	Sheet: 1 of 1



ITEM	QUAN'	TITY	MATTERIAL	amo ave veo
NO.	Galv.	SS	MATERIAL	STOCK NO.
78B		1	CRIMPIT - CTYPE, COPPER, #2-#6 AWG	253-00004
135E		1	BOLT - MACH. 5/8" x 12", SS	098-00039
143		1	NUT, SQUARE, 5/8", SS	565-00009
149		2	SCREW - LAG, TWIST DRIVE/DRIVE POINT, 1/2" X 3", SS	744-00003
153		1	WASHER - FLAT SQ., 2 1/4", 11/16" HOLE, SS	973-00009
158		1	WASHER - LOCK, 5/8", SINGLE COIL, SS	973-00010
162		1	CLIP-GROUND WIRE BONDING, 5/8", SS	188-00004
406B		1	ARM, LIGHT ALUMINUM - 2" X 8'	035-00005
408A		1	PHOTOCELL ELECTRONIC	597-00001
412		2	CONNECTOR, INSULATED PIERCING, TYPE EPB	213-00027
416		1	LUMINAIRE, LED 137W	520-00007

1. Each streetlight shall be grounded inside the luminaire and also the ground shall be connected to the neutral on both primary and secondary poles.

	Date: September 2017  Drawn by: D. Moore	DISTRIBUTION STANDARDS	
LUC		137W LED 8FT. ARM INSTALLATION	
You've got the power	Revision #: B		
457 North Sound Rd. P.O. Box 38 G.T., Grand Cayman,	Revision date: November 23, 2020	Approved date: November 23, 2020	STANDARD # 14-4
Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200	Revised by: C. Craig	Approved by: N. Malcolm	Sheet: 1 of 1



ITEM	QUAN'	ITTY	MATERIAL	GTO GIV NO
NO.	Galv.	SS	MATERIAL	STOCK NO.
78B		1	CRIMPIT - CTYPE, COPPER, #2-#6 AWG	253-00004
135E		1	BOLT - MACH. 5/8" x 12", SS	098-00039
143		1	NUT, SQUARE, 5/8", SS	565-00009
149		2	SCREW - LAG, TWIST DRIVE/DRIVE POINT, 1/2" X 3", SS	744-00003
153		1	WASHER - FLAT SQ., 2 1/4", 11/16" HOLE, SS	973-00009
158		1	WASHER - LOCK, 5/8", SINGLE COIL, SS	973-00010
162		1	CLIP-GROUND WIRE BONDING, 5/8", SS	188-00004
406B		1	ARM, LIGHT ALUMINUM - 2" X 8'	035-00005
408A		1	PHOTOCELL ELECTRONIC	597-00001
412		2	CONNECTOR, INSULATED PIERCING, TYPE EPB	213-00027
417		1	LUMINAIRE, LED 207W	520-00006

1. Each streetlight shall be grounded inside the luminaire and also the ground shall be connected to the neutral on both primary and secondary poles.

	Date: September 2017  Drawn by: D. Moore	DISTRIBUTION STANDARDS	
		207W LED 8FT. ARM INSTALLATION	
You've got the power	Revision #: B		
457 North Sound Rd. P.O. Box 38 G.T., Grand Cayman,	Revision date: November 23, 2020	Approved date: November 23, 2020	STANDARD # 14-5
Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200	Revised by: C. Craig	Approved by: N. Malcolm	Sheet: 1 of 1

### **UNDERGROUND STREET LIGHTING**

All underground street lights are typically one of three types:

- 20' aluminum pole with one or two 53 watt LED lights on a 6'arm (Drawing 14-9)
- 35' aluminum pole with one or two 137 watt LED lights on a 6'arm (Drawing 14-10)
- 50' aluminum pole with four 207 watt LED lights on a 8' arm (Drawing 14-11)

#### **General Rule for Connection Design:**

• Standard 16 & maximum 18 lights can be installed either side of the connection point for 53 and 137 watt lights and maximum 12 lights either side of the connection point for 207 watt lights.

#### **Ducting:**

- Conduit size shall be 2" schedule 40.
- A draw string shall be installed in conduit by contractor, at the time of installation.
- Depth of conduit to be a minimum of 18". If it is less than 18" it must have a minimum of 2" concrete cover. All road crossing must be encased in concrete.
- A galvanized rigid steel elbow encased in concrete is required at the base of the pole. The first section of the conduit (10') at the base of the pole must be galvanized rigid steel.
- A separate ground will be required for services greater than 240 volts and attached to the conduit with a ground bracket, this will be connected by CUC staff.

#### Wire Size:

• The standard wire size will be #6/3 core fully insulated.

#### Distance between base pedestals:

• Distance between base pedestals will be determined from lighting designs to meet the required design criteria.

### **Base Templates:**

• Please refer to Drawings: 14-9 (20' Base), 14-10 (35' Base) and 14-11 (50' Base) for base template information & measurements.

### **Procedure to Install Light:**

- Ensure that the light base pedestal is level (By Contractor)
- Use draw rope to pull in feed conductor.
- Install light Pole (ensuring it is plumb)
- Install and connect light
- Install Cover On Bolts

	Date: June 21, 2017	DISTRIBUTION STANDARDS	
	Drawn by: C. Rose		
		STREET & SECURITY LIGHTING	
You've got the power	Revision #: B		
457 North Sound Rd. P.O. Box 38 G.T., Grand Cayman,	Revision date: November 23, 2020	Approved date: December 7, 2020	STANDARD # 14-7
Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200	Revised by: N Malcolm	Approved by: N. Malcolm	Page: 1 of 1


## Procedure To Install Fuse Disconnect Switch On a Secondary Feed Pole:

- A fuse disconnect switch (CUC stock item) will be mounted above the 10' galvanized conduit.
- (2)-60amp blade type fuse to be installed to protect against short circuits such as a motor vehicle accident.
- Install 2" PVC conduit with weatherhead on pole (2" straps & weatherhead to be purchased locally as not a CUC stock item).
- Install #4 TEK cable for secondary feed for fuse disconnect switch
- Fuse disconnect switch to be grounded as per CUC standards

### **Padmount Transformer Connections For Underground Lighting Installation:**


- Fuse disconnect switch to be mounted on a pedestal that will need to be constructed on the transformer vault.
- Install #4 TEK cable from secondary source to fuse disconnect switch.
- Install #6/3 core cable from switch to lights.
- Fuse disconnect switch to be grounded as per CUC standards.


	Date: June 21, 2017	DISTRIBUTION STANDARDS	
	Drawn by: C. Rose		
		STREET & SECURITY LIGHTING	
You've got the power	Revision #: B		
457 North Sound Rd. P.O. Box 38 G.T., Grand Cayman,	Revision date: November 23, 2020	Approved date: December 7, 2020	STANDARD # 14-8
Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200	Revised by: N Malcolm	Approved by: N. Malcolm	Page: 1 of 1



- 1. Streetlight shall be grounded inside the base of the pole.
- 2. Warning: Do not install light pole without luminaire.

	Date: December 7, 2020	DISTRIBUTION STANDARDS		
	Drawn by: C. Craig			
		20FT. ALUMINUM POLE FOR STREETLIGHT		
You've got the power	Revision #:	UNDERGROUND CABLE		
457 North Sound Rd. P.O. Box 38 G.T., Grand Cayman, Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200	Revision date:	Approved date: December 7, 2020	STANDARD # 14-9	
	Revised by:	Approved by: N. Malcolm	Sheet: 1 of 1	







E LINE
You've got the power

457 North Sound Rd. P.O. Box 38 G.T., Grand Cayman, Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200

	Date: June 2012	DISTRIBUTION STANDARDS		
,	Drawn by: D. Moore			
		35FT. ALUMINUM POLE FOR STREETLIGHT UNDERGROUND CABLE		
	Revision #: B			
	Revision date: December 7, 2020	Approved date: December 7, 2020	STANDARD # 14-10	
	Revised by: C. Craig	Approved by: N. Malcolm	Sheet: 2 of 2	





E TIM
You've got the power

457 North Sound Rd. P.O. Box 38 G.T., Grand Cayman, Cayman Islands, B.W.I. Telephone: (345)-949-5300/5200

	Date: June 2012	DISTRIBUTION STANDARDS		
,	Drawn by: D. Moore			
		50FT. ALUMINUM POLE FOR STREETLIGHT		
	Revision #: B	UNDERGROUND CABLE		
	Revision date: December 7, 2020	Approved date: December 7, 2020	STANDARD # 14-11	
	Revised by: C. Craig	Approved by: N. Malcolm	Sheet: 2 of 2	